




## **EXHIBIT C-3**

**APPENDIX A**







### TYPICAL POWER SERVICE FOR NEWSTAND

#### **NOTE:**

CONNECTION TO LIGHTING CIRCUIT THROUGH SA. FUSE INSIDE  
OPW LIGHTING STANDARD HAND HOLE.

**PB PARSONS  
BRINCKERHOFF**

303 SECOND ST. SUITE 700N. SAN FRANCISCO, CA


SCALE	DATE	SHEET
NONE	03DEC98	SKE-001

$\frac{3}{4}$ " RGS CONDUIT  
#2-#14 Cu TO  
LIGHTING FIXTURES

NEW  
NEWSTAND

$\frac{3}{4}$ " RGS CONDUIT

100A-10. 3W.  
120/208V.  
METER SOCKET  
SEE NOTE NO. 1



**TYPICAL POWER SERVICE  
FOR NEWSTAND**  
(UTILITY ONLY)

**NOTES:**

1. REQUIREMENTS FOR MEETING SHALL BE COORDINATED WITH UTILITY.
2. SERVICE CONDUIT LOCATION AND SUB-OUT TO BE COORDINATED WITH UTILITY.

**PB PARSONS  
BRINCKERHOFF**

303 SECOND ST. SUITE 700M. SAN FRANCISCO. CA

SCALE  
NONE

DATE  
03DEC98

SHEET  
SKE-002

8. For single-family residences, the electric meter should normally be located in the same general area as the gas meter. Refer to Section 2, Figure 10, for required clearances.
9. All meter installations require prior PG&E review and approval. When meter(s) is (are) installed in a confined or enclosed area, a means (e.g., window, opening, etc.) to read the meter(s) from an external location should be provided.

#### 4. Single Meter Sockets and Mounting - Single Residence, Underground

##### A. Single Metered Residence, 0 to 200 Amperes, 1Ø.

For a single underground residential service to be metered by a self-contained meter, the customer shall furnish, install, and maintain a 4-terminal socket similar to that shown in Figure 1 for 120V/240 V service (5-terminal for 120V/208 V service). PG&E's service conductors will be connected to termination lugs in the underground service termination section.




Figure 1  
Typical UG Service Termination Enclosure  
Combination Meter Socket Panel (Residential 0-225 Amp)

Socket Rating Amps	X Min. Dim.	Y Min. Dim.
Up to 125	8"	4"
200	11"	5-1/2"

**Notes:**


1. The socket and enclosure shall be specifically designed to receive service conductors from an underground supply system. Enclosures designed for either overhead or underground service entry are acceptable provided they meet all requirements for both types.

## SINGLE METER SOCKET KEYS




All sockets are rated 500V ac max. and either 100 or 200 amps continuous. All have a short circuit rating of 10,000 rms symmetrical amperes (watt-hour meter is not included in rating).

All single meter sockets are UL labeled and are supplied in surface mounted outdoor enclosures. Confirm local utility acceptance prior to order entry.




UR5101CH




UR5212ACH

## SINGLE METER SOCKETS

Continuous Duty Amp	Volts Ac	Center Dimensions @ Inches			Weight (Lbs.)	Dimensions and Knockout Figure No.	Line and Load Wire Range Cu/Al	Hub or Hub Provision		List Price	NAED Number
		H	W	D							
Ringless Type No By-Pass In. 3W											
100	500	12-1/4	8-1/2	4-1/4	7	A	#8 - 2/0	Prev. only ①	UR5101CH	\$ 72.	00398
200		15-1/2	11-1/2	5	13	O	#8 - 250 MCM	None ②	UR5212CH	128.	00398
200		15-1/2	11-1/2	5	13	E	#8 - 250 MCM	None ②	UR5212ACH	128.	00400
200		15-1/2	8-1/2	5	11	E	#8 - 250 MCM	2 in. Hub ③	UR5207CH	115.	00401
200		15-1/2	8-1/2	5	11	E	#8 - 250 MCM	Prev. only ③	UR5207ACH	110	00402
Ringless Type with Main By-Pass In. 3W											
200	500	15-1/2	8-1/2	5	11	E	#8 - 250 MCM	Prev. only ③	UR5207CH	115.	00403
200		15-1/2	11-1/2	5	13	E	#8 - 250 MCM	None ②	UR5212ACH	128.	00404
Ring Type No By-Pass In. 3W (Supplied with stainless steel, snap type locking ring)											
100	500	12-1/4	8-1/2	4-1/4	7	A	#8 - 2/0	1-1/4 in. Hub ③	UR5101CH	74.	00405
200		15-1/2	11-1/2	5	14	C	1/0 - 350 MCM	Closure Pull ③	UR5212CH	132.	00406

## ACCESSORIES FOR SINGLE METER SOCKETS




ARP00035CH1

ARP00036CH2

Catalog Number	Description	List Price	NAED Number
ARP00035CH1	Hub Closure Plate	\$ 8.40	00407
ARP00036CH2	1 in. Hub	17.90	00408
ARP00037CH3	1-1/4 in. Hub	17.90	00408
ARP00038CH4	1-1/2 in. Hub	17.90	00410
ARP00039CH5	2 in. Hub	29.00	00411
ARP00040CH6	2-1/2 in. Hub	31.00	00412
ARP00041CH7	3 in. Hub	31.00	00413

- ① Bottom service cable entry only.
- ② Top service cable entry only.
- ③ Suitable for either top or bottom service cable entry.
- ④ Set jam can be installed in either the 3 or the 9 o'clock position.
- ⑤ Carton quantity, 1.

## DIMENSIONS AND KNOCKOUT ILLUSTRATIONS



NOTE: Dimensions shown are approximate. They represent inside dimensions of enclosure and do not include mounting brackets or cover protrusions.

DISCOUNT STANDARD 22-00

E.T.N

BB-1

July 1985



# CUTLER-HAMMER SAFETY SWITCHES


## General Duty

DP, DG


### WHEN ORDERING SPECIFY

- Catalog Number

- UL Listed, File E5238.
- Meets UL 98 for enclosed switches and NEMA Std. KS-1.
- Suitable as service entrance equipment, when applied with neutral or ground Lug Kit.



Type DP with Plug Fuse Provision





Type DG 60 Amps, Range

**FUSIBLE** — Higher Hp ratings apply when time delay fuses are used.

System	Ampere	Type of Fuse Provision	Indoor Type I Enclosure		Rainproof Type 3R Enclosure		Maximum Horsepower				Peak Quantity	
			Catalog Number	List Price	Catalog Number	List Price	Single Phase		3 Phase	60		
							120V	240V	240V	250V		
2 WIRE S/N (1 BLADE, 1 FUSE) 120 VOLTS AC												
	30	Plug	DP111NGB	\$ 41.	DP111NRB	\$ 65.	1/2	...	...	...	...	6
3 WIRE S/N (2 BLADES, 2 FUSES) 120/240 VOLTS AC (PLUG & CART.) 240 VOLTS AC (CARTRIDGE)												
	30	Plug	DP221NGB	\$ 46.38	DP221NRB	\$ 91.	1/2	1-1/2	...	2	6	6
	60	Class M	DG221NGB	107.	DG221NRB	67.	2	1-1/2 - 3	3 - 7-1/2	...	...	6
	100	Class M	DG222NGB	222.	DG222NRB	170.	1-1/2 - 3	3 - 10	7-1/2 - 15	...	...	6
	200	Class M	DG224NGK	439.	DG224NRK	250.	...	7-1/2 - 15	15 - 30	...	...	1
	400	Class M	DG225NGK	1293.	DG225NRK	1740.	...	15	25 - 50	...	...	1
	600	Class M	DG226NGK	2818.	DG226NRK	3368.	...	...	50 - 125	50	...	1
3 POLE, 240 VOLTS AC												
	20-200	Class M	DG325FGK	1367.	DG325FRK	1781.	...	...	50 - 125	50	...	1
	400	Class M	DG326FGK	2908.	DG326FRK	4014.	...	...	75 - 200	...	...	1
4 WIRE S/N (3 BLADES, 3 FUSES) 240 VOLTS AC												
	30	Class M	DG321NGB	99.	DG321NRB	150.	...	1-1/2 - 3	3 - 7-1/2	...	...	6
	60	Class R	DG321NGK	128.	DG321NRK	181.	...	1-1/2 - 3	3 - 7-1/2	...	...	6
	100	Class R	DG322NGK	170.	DG322NRK	228.	1-1/2 - 3	3 - 10	7-1/2 - 15	...	...	1
	200	Class R	DG324NGK	281.	DG324NRK	418.	1-1/2 - 3	3 - 10	7-1/2 - 15	...	...	1
	400	Class M	DG325NGK	621.	DG325NRK	758.	...	7-1/2 - 15	15 - 30	...	...	1
	600	Class M	DG326NGK	1582.	DG326NRK	1958.	...	15	25 - 50	...	...	1
		Class H	DG328NGK	2178.	DG328NRK	4158.	...	...	50 - 125	50	...	1
							...	...	75 - 200	...	...	1

### NON-FUSIBLE

System	Ampere	Indoor Type I		Rainproof Type 3R		Maximum Horsepower			Peak Quantity
		Catalog Number	List Price	Catalog Number	List Price	14 ac	30 ac	250V dc	
2 POLE, 240 VOLTS AC									
	30	DG221UGB	\$ 74.	DG221URB	\$ 117.	3	...	...	6
	60	DG222UGB	...	DG222URB	208.	10	...	...	1
3 POLE, 240 VOLTS AC									
	30	DG321UGB	61.	DG321URB	150.	3	7-1/2	...	6
	60	DG322UGB	108.	DG322URB	228.	10	15	...	1
	100	DG324UGB	280.	DG324URB	418.	15	30	...	1
	200	DG325UGB	441.	DG325URB	744.	15	60	...	1
	400	DG326UGB	1077.	DG326URB	1799.	...	125	50	1
	600	DG328UGB	2128.	DG328URB	3322.	...	200	...	1

© Grounded 3 Phase Racalco 15' Lead

- ⊙ Grounded 3 Phase Ratings, UL listed.
- ⊙ Use 4-wire, Solid Neutral System.

- ⊙ Not suitable as service entrance equipment.
- ⊙ Suitable for 400-600A rated 240V ac, 250V dc.

E.T.N

DD-4

DISCOUNT SYSTEMS LTD.

July 1993

APPENDIX B

Form of Faithful Performance Supply & Installation Bond

\_\_\_\_\_(Surety)

KNOW ALL MEN BY THESE PRESENTS:

That we [Name of Contractor] as Principal, and [Surety Company], a \_\_\_\_\_, as Surety, are held and firmly bound into the City and County of San Francisco, as Obligee, in the sum of \_\_\_\_\_ (\$\_\_\_\_\_) lawful money of the United States of America, to be paid to the City and County of San Francisco for which payment, well and truly to be made, we bind ourselves, our heirs, executors and successors jointly and severally, firmly by these presents.

THE CONDITION OF THE FOREGOING OBLIGATION is such that

WHEREAS, the Principal has entered into an Agreement, effective \_\_\_\_\_, 20\_\_\_\_, with the City and County of San Francisco, for the installation of pedestal mounted newsracks on public property and is required to give this bond in connection with the installation of the pedestal mounted newsracks.

NOW, THEREFORE, the condition of this obligation is such that if the Principal shall faithfully supply and install all of the Fixed Pedestal Units required under the Agreement consistent with all of the covenants, terms and conditions of said Agreement (which by reference is made a part hereof), then this obligation shall be null and void, otherwise to remain in full force and effect; and shall be effective \_\_\_\_\_, 20\_\_\_\_; provided that the Surety hereby agrees to give at least thirty (30) days written notice by certified mail to the City at the following address prior to the expiration or any termination of this bond for any reason: Director of the Department of Public Works for the City and County of San Francisco, c/o San Francisco Department of Public Works, City Hall, Room 348, 1 Dr. Carlton B. Goodlett Place, San Francisco, CA 94102, and the Controller, City and County of San Francisco, Office of the Controller, City Hall, Room 316, 1 Dr. Carlton B. Goodlett Place, San Francisco, CA 94102.

Surety, for value received, hereby stipulates and agrees that no change, extension of time, alteration or addition to the terms of the contract or to the work to be performed thereunder or to the specifications accompanying the same shall in any wise affect its obligations on this Bond, and it does hereby waive notice of any such change, extension of time, alteration or addition to the terms of the contract or the work or the specifications.

Signed, sealed and dated this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

Principal:

\_\_\_\_\_  
Surety: